

EagleRidge High School Water Testing Results

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID#	Test Date	Test Result
Sink - Room 39	21413	10/16/2016	0.740 ppb
Water fountain 1	21396	10/16/2016	0.194 ppb
Men's staff bathroom	21384	10/16/2016	0.579 ppb
Women's staff bathroom	21414	10/16/2016	.0682 ppb
Boy's bathroom west side	21379	10/16/2016	1.05 ppb
Girl's bathroom west side	21400	10/16/2016	0.780 ppb
Kitchen	21415	10/16/2016	1.68 ppb
Janitor's closet	21374	10/16/2016	3.90 ppb
Science room sink 1	21378	10/16/2016	1.80 ppb
Science room sink 2	21409	10/16/2016	0.777 ppb
Science room sink 3	21373	10/16/2016	1.90 ppb
Science room sink 4	21382	10/16/2016	0.972 ppb
Science prep room sink	21372	10/16/2016	18.8 ppb
Sink - Room 31	21411	10/16/2016	11.4 ppb
Boys bathroom east side	21405	10/16/2016	0.466 ppb
Girls Bathroom east side	21399	10/16/2016	0.439 ppb
Water fountain 2	21402	10/16/2016	0.290 ppb
Bathroom Elm Ave Ste F	21410	10/16/2016	1.23 ppb
Bathroom Elm Ave Ste E	21408	10/16/2016	2.72 ppb

The Science prep room sink and the Sink Room 31 have been turned off and disconnected.